



DISTRICT OF COLUMBIA COURTS  
Capital Projects and Facilities Management  
Office: Gallery Place  
616 H Street NW, 6<sup>th</sup> Floor  
Washington, DC 20001  
Mailing Address: 500 Indiana Avenue NW  
Washington, DC 20001-2131



Cheryl R. Bailly, Ph.D.  
Acting Executive Officer

**AMENDMENT NO. 004**

**TO: ALL PROSPECTIVE BIDDERS**

**AMENDMENT  
ISSUE DATE: July 7, 2021**

**SUBJECT: Solicitation No. DCSC-21-RFP-085  
HCMC 4<sup>th</sup> Floor East Magistrate Judges Suite Renovation**

**PROPOSAL  
SUBMISSION  
DATE: Tuesday, July 13, 2021, by 3:00 pm,  
Eastern Standard Time**

The subject request for Amendment #04, for solicitation DCSC-21-RFP-085 issued on June 09, 2021, is amended as follows:

**The RFP, Closing Date & Time is hereby “CHANGED” from July 9, 2021, by 3:00 pm EST, to July 13, 2021 by 3:00 pm EST. If you have submitted a proposal you may rescind it and resubmit according to the amended submission date.**

Question and Answers Round – 4

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED**

One (1) copy of this amendment is being sent to all prospective Offerors. The prospective Offeror shall sign below and attach a signed copy of this amendment to each proposal to be submitted to the Courts in response to the subject solicitation or otherwise acknowledge this amendment with the signed offer as stated in the original solicitation documents. Proposals shall be delivered in accordance with the instructions provided in the original solicitation documents.

---

Geoffrey Mack  
Contracting Officer

Acknowledgement of this Amendment, together with the Offeror's proposal, must be received by the District of Columbia Courts as stated in the solicitation no later than the closing date and time specified above for the receipt of proposals.

Failure by the Offeror to properly acknowledge receipt of this Amendment Number #04 may be cause for rejection of the proposal submitted by the Offeror in response to the subject solicitation.

**This Amendment Number #04 is acknowledged and is considered a part of the proposal for Solicitation Number DCSC-21-RFP-085 HCMC 4<sup>th</sup> Floor East Magistrate Judges Suite Renovation**

\_\_\_\_\_  
Signature of Authorized Representative

\_\_\_\_\_  
Date

\_\_\_\_\_  
Name of Authorized Representative

\_\_\_\_\_  
Title of Authorized Representative

\_\_\_\_\_  
Name of Offeror

**Please remember to check the DC Courts Website daily for posting of Amendment updates**

<https://www.dccourts.gov/about/procurement-contracts-branch>

<b>From:</b> Kenneth L. Evans	<b>Q &amp; A Round:</b> 4
<b>Program:</b> Capital Project Facilities Management Division	<b>Date:</b> July 7, 2021
<b>Email:</b> <a href="mailto:Kenneth.Evans@dccsystem.gov">Kenneth.Evans@dccsystem.gov</a>	<b>Pages:</b> 3

<b>cc:</b> <a href="mailto:Judith.Hill@dccsystem.gov">Judith.Hill@dccsystem.gov</a>	DC Courts
<b>cc:</b> <a href="mailto:Mia.Sensabaugh@dccsystem.gov">Mia.Sensabaugh@dccsystem.gov</a>	AECOM
<b>cc:</b> <a href="mailto:Clay.McKenna@dcsc.gov">Clay.McKenna@dcsc.gov</a>	AECOM
<b>cc:</b> <a href="mailto:Richard.Moore@dcsc.gov">Richard.Moore@dcsc.gov</a>	AECOM

**This Document includes the following:**

-Solicitation Questions & Answers Round: 04

**SOLICITATION QUESTIONS & ANSWERS: ROUND 04**

- Q.1 What is to be the thickness of the terrazzo floor and terrazzo base? (It is indicated as 1/2” on detail 40 on 2.A.961 but measures at 3/8”)
- A.1 **The correct thickness is to be 3/8" thick for both the floor and the base.**
- Q.2 The specs are calling for plastic divider strips but the base detail shows an aluminum strip. Which one is to be used?
- A.2 **Provide aluminum strips per the base detail.**

**Please remember to check the DC Courts Website daily for posting of Amendment updates**

<https://www.dccourts.gov/about/procurement-contracts-branch>